

Q & A's

Date: November 22, 2010

Please find below technical questions asked by a vendor and M-DCPS response to each.

1) Ames 2000B $\frac{3}{4}$ Backflow: Is this unit classified as an "M1" or "M2"?

M2. (ADDENDUM NO. 2 BID #1)

2) Febco 805 $\frac{3}{4}$ Backflow: Is this an 805 "Y""YB" or "YS" or "YR" type unit?

805Y. (ADDENDUM NO. 2 BID #12)

3) Febco 806 4" Backflow: Is this an 806DCDA or an 806 YD?

806 YD. (ADDENDUM NO. 2 BID #13)

4) Hersey DDCII $\frac{3}{4}$ Backflow: Is this correct? Could it be a 3" backflow instead of a $\frac{3}{4}$ unit?

Hersey DDCII 3" Backflow. (ADDENDUM NO. 2 BID #21)

5) Hersey 60M 4" Backflow: Is this correct? Based on the information, could it be a 6CM instead of a 60M?

Hersey 6CM 4". (ADDENDUM NO. 2 BID #22)

6) Watts 007 $\frac{3}{4}$ Backflow: Is this an M2 or M3 Unit?

M2. (ADDENDUM NO. 2 BID #23)

7) Watts 009 2" Backflow: Is this an 009, 009M1 or an 009M2 unit and is it Stainless Steel or not?

Remains 009. (ADDENDUM NO. 2 BID #25)

8) Watts 709 $\frac{3}{4}$ Backflow: Is this a Stainless Steel Backflow or a regular bronze unit?

Bronze. (ADDENDUM NO. 2 BID #26)

9) Watts 909 4" Backflow: Is this assembly an M1 or not?

Remains 909. (ADDENDUM NO. 2 BID #32)

10) Wilkins 875 2" Backflow: Is this the correct model? Wilkins does not make an 875. Could it be instead a 975XL or a 975XLT 2"?

975XL. Item 39 on the original Bid Proposal Form was deleted because it is now the same as Item 42, 975XL. The quantity of 1 was added to Item 42 on Addendum No. 2 Bid Proposal Form. **(ADDENDUM NO. 2 BID #42)**

11) Wilkins 950 ¾ Backflow: Is this a 950XL or a 950 XLT?

950XL. **(ADDENDUM NO. 2 BID #39)**

12) Wilkins 950 4" Backflow: Is this a 950XL or a 950 XLT?

950XL. **(ADDENDUM NO. 2 BID #40)**

13) Wilkins 975 6" Backflow: Is this a 975 or a 975DA? Also, it shows two line items for this unit, Line Item # 42 & 47. Is it safe to say that there are a total of 3 units?

975. Item 47 on the original Bid Proposal Form was deleted because it is now the same as Item 41, 975. The quantity of 1 was added to Item 41 on Addendum No. 2 Bid Proposal Form. **(ADDENDUM NO. 2 BID #41)**

14) Wilkins 9752-1/2", 3", 4" Backflow: Are these units 975 or 975DA?

Remains 975 for Items 43, 44, and 45. **(ADDENDUM NO. 2 BID #43, 44, AND 45)**